Autonics

DIGITAL PANEL METER **M4N SERIES**

М



Thank you very much for selecting Autonics products For your safety, please read the following before using.

Caution for your safety

*Please keep these instructions and review them before using this unit.

*Please observe the cautions that follow;

↑Warning Serious injury may result if instructions are not followed.

∧ Caution

Product may be damaged, or injury may result if instructions are

*The following is an explanation of the symbols used in the operation manual A caution: Injury or danger may occur under special conditions.

/!\ Warning

1. In case of using this unit with machineries (Nuclear power control, medical equipment, vehicle, train, airplane, combustion apparatus, entertainment or safety device etc), it requires installing fail-safe device, or contact us for information on type required.

It may result in serious damage, fire or human injury.

- 1. It must be mounted on panel.
- It may give an electric shock
- 2. Do not repair, check up or connect when power on and measuring input applied. It may give an electric shock.
- 3. Do not disassemble and modify this unit, when it requires. If needs, please contact us.


It may give an electric shock and cause a fire.

- 4. This unit shall not be used outdoors.
- It might shorten the life cycle of the product or give an electric shock.
- 5. Please observe specification rating.
- It might shorten the life cycle of the product and cause a fire.
- 6. Be sure that there is not insulated between measuring input terminal and power terminal.
- It may cause mechanical trouble of measuring target or result in product damage.
- 7. Please separate the power supply in case of using multiple units at the same time

It may cause mechanical trouble of measuring target or result in product damage.

- 8. Please wire properly after check polarity of power.
- It may cause a fire or explosion and result in product damage.
- 9. In cleaning the unit, do not use water or an oil-based detergent. It might cause an electric shock or fire that will result in damage to this product.
- 10. Do not use this unit at place where there are flammable or explosive gas, humidity, direct ray the sun, radiant heat, vibration, impact etc.
- It may cause explosion.
- 11. Do not inflow dust or wire dregs into inside of this unit.
- It may cause a fire or mechanical trouble.
- 12. Please connect properly after checking the polarity of measuring terminals.
- * The above specifications are subject to change and some models may be discontinued without notice.

Ordering information




- *1: M4N series is to measure DC only, AC voltage and AC current is not available to be
- ※2: 1-5VDC measuring input is optional.

Specifications

Model		M4N-DV-	M4N-DA-□□	M4N-DI-
Measurement function		DC voltage	DC Ampere	DC4-20mA
Power supply		5VDC, 12-24VDC		
Allowable voltage range		90~110% of rated voltage		
Power consumption		2W		
Display method		7Segment LED Display(Character height: 10mm)		
Max.display range		Max. 1999		
Display accuracy		F.S. \pm 0.2% rdg \pm 1digit		
Sampling cycle		300ms		
A/D conversion method		Dual intergal method		
Response time		Approx. 2sec.(0 to 1999)		
Max.allowable input		150% of measurement input range		
Sampling time		2.5 times/sec		
Insulation resistance		Min. 100MΩ(at 500VDC megger)		
Dielectric strength		2000VAC 50/60Hz for 1 minute		
Noise strength		±100V the square wave noise(pulse width: 1μs) by the noise simulator		
Vibra -tion	Mechanical	0.75mm amplitude at frequency of 10 ~ 55Hz in each of X, Y, Z directions for 1hour		
	Malfunction		5mm amplitude at frquency of 10 ~ 55Hz each of X, Y, Z directions for 10minutes.	
Shock	Mechanical	300m/s ² (30G) in X, Y, Z direction		
	Maltunction		100m/s ² (10G) in X, Y, Z direction	
Environ	Ambient temperature	-10 ~ 50℃, Storage temperature: -20 ~ 60℃		
-mnet	Ambient humidity	35 ~ 85%RH, Storage humidity: 35 ~ 85%RH		
Weight		Approx. 44g		

*Environment resistance is rated at no freezing or condensation.

Connections




*1:5VDC, 12-24VDC

*When changing the position of the decimal point, disconnect switching pattern point on PCB and change the decimal point in external terminal socket.

Dimensions


(Unit:mm) ●Panel cut—out 37 22 Min 60 199.9 ●48×24 Bracket

Mounting



※Panel boad tickness should be less than 10.0mm.

General block diagram




use shunt. If measure higher voltage than measuring input range please use multiplier.

★ If use a voltage measurement function meter and a ampere measurement function meter to a set, please use DC power 1FA individually

※1:When measure over DC2A, please use Shunt.

Caution for using

- 1. Please use separated line from high voltage line or power line in order to avoide inductive
- 2. Please use power switch or circuit breaker in order to turn OFF the power.
- 3. The switch or circuit—breaker should be installed near by users for safety.
- 4. Be sure to avoid using this unit near by machinery makes strong high frequency noise. (Welding machine high, capacity SCR unit etc.)
- 5. When input applied, if "I" or "I" are displayed, it has some trouble with measuring input, please check the line after power off.
- 6. Input line: Shield wire must be used when the measuring input line is getting longer or there are lots of noises.



7. Please use insulated transformer for power supply

*It may cause malfunction if above instructions are not followed.

Main products

■ Photoelectric sensors ■ Temperature controllers ■ Fiber optic sensors ■ Temperature/Humidity transducers ■ SSR/Power controllers

■ Door sensors Door side sensors

Area sensors ■ Timers

Proximity sensors Panel meters ■ Tachometer/Pulse(Rate)meters Pressure sensors Rotary encoders ■ Display units

■ Connector/Sockets ■ Sensor controllers ■ Switching mode power supplies

Control switches/Lamps/Buzzers ■ I/O Terminal Blocks & Cables

Stepper motors/drivers/motion controllers ■ Graphic/Logic panels Field network devices

■ Laser marking system(Fiber, CO₂, Nd:YAG) Laser welding/soldering system

Autonics Corporation http://www.autonics.com

Satisfiable Partner For Factory Automation

HEAD QUARTERS:

18, Bansong-ro 513beon-gil, Haeundae-gu, Busan, Korea OVERSEAS SALES:

#402-404, Bucheon Techno Park, 655, Pveongcheon-ro. Wonmi-gu, Bucheon, Gyeonggi-do, Korea TEL: 82-32-610-2730 / FAX: 82-32-329-0728

■ E-mail: sales@autonics.com

EP-KE-04-0010G