

# CMC-MOD01

2013-12-15  
5011693402-CMO2

## Instruction Sheet

## 安裝說明 安装说明

MODBUS TCP Communication Card

MODBUS TCP 通訊卡

MODBUS TCP 通讯卡



Smarter. Greener. Together.

## Warning .....

**EN** CMC-MOD01 is an OPEN-TYPE device. It should be installed in a control cabinet free of airborne dust, humidity, electric shock and vibration. To prevent non-maintenance staff from operating CMC-MOD01, or to prevent an accident from damaging CMC-MOD01, the control cabinet in which CMC-MOD01 is installed should be equipped with a safeguard. For example, the control cabinet in which CMC-MOD01 is installed can be unlocked with a special tool or key.

**EN** DO NOT connect AC power to any of I/O terminals; otherwise serious damage may occur. Please check all wiring again before CMC-MOD01 is powered up. After CMC-MOD01 is disconnected, Do NOT touch any terminals in a minute. Make sure that the ground terminal on CMC-MOD01 is correctly grounded in order to prevent electromagnetic interference.

**FR** CMC-MOD01 est un module OUVERT. Il doit être installé dans une enceinte protectrice (boîtier, armoire, etc.) saine, dépourvue de poussière, d'humidité, de tension et hors d'atteinte des chocs électriques. La protection doit éviter que les personnes non habilitées à la maintenance puissent accéder à l'appareil (par exemple, une clé ou un outil doivent être nécessaire pour ouvrir la protection).

**FR** Ne pas appliquer la tension secteur sur les bornes d'entrées/Sorties, ou l'appareil CMC-MOD01 pourra être endommagé. Merci de vérifier encore une fois le câblage avant la mise sous tension du CMC-MOD01. Lors de la déconnection de l'appareil, ne pas toucher les connecteurs dans la minute suivante. Vérifier que la terre est bien reliée au connecteur de terre afin d'éviter toute interférence électromagnétique.


## 1 Introduction

Thank you for choosing Delta CMC-MOD01 communication card. CMC-MOD01 is a MODBUS TCP communication card for connecting Delta C2000 series, CH2000 series, CP2000 series, CT2000 series, and AFE2000 series AC motor drives to MODBUS TCP network. No external power supply is required for CMC-MOD01. The power will be supplied by an AC motor drive.

### ■ Functions

- Supports MODBUS TCP protocol
- MDI/MDI-X auto-detect
- Baud rate: 10/100Mbps auto-detect
- E-mail alarm
- AC motor drive keypad/Ethernet configuration
- Virtual serial port

### ■ Product Profile



[Figure 1]

- Screw fixing hole
- Positioning hole
- AC motor drive connection port
- LINK indicator
- RJ-45 connection port
- POWER indicator
- Fool-proof groove

## 2 Specifications

### ■ Network Interface

Interface	RJ-45 with Auto MDI/MDIX
Number of ports	1 Port
Transmission method	IEEE 802.3, IEEE 802.3u
Transmission cable	Category 5e shielding 100M
Transmission speed	10/100 Mbps Auto-Detect
Network protocol	ICMP, IP, TCP, UDP, DHCP, HTTP, SMTP, MODBUS OVER TCP/IP, Delta Configuration

### ■ Electrical Specification

Weight	25g
Insulation voltage	500VDC
Power consumption	0.8W
Power supply voltage	5VDC

### ■ Environment


Noise immunity	ESD (IEC 61800-5-1, IEC 61000-4-2) EFT (IEC 61800-5-1, IEC 61000-4-4) Surge Test (IEC 61800-5-1, IEC 61000-4-5) Conducted Susceptibility Test (IEC 61800-5-1, IEC 61000-4-6)
Operation/storage	Operation: -10°C ~ 50°C (temperature), 90% (humidity) Storage: -25°C ~ 70°C (temperature), 95% (humidity)
Vibration/shock immunity	International standard: IEC 61800-5-1, IEC 60068-2-6/IEC 61800-5-1, IEC 60068-2-27

### ■ Installation

Note: The contents below are about installing CMC-MOD01 on C2000.

### ■ Connecting CMC-MOD01 to Network

- Switch off the power of AC motor drive.
- Open the front cover of the AC motor drive.
- Connect CAT-5e network cable to RJ-45 port on CMC-MOD01 (See Figure 2).



[Figure 2]

### ■ RJ-45 PIN Definition

PIN	Signal	Definition
1	Tx+	Positive pole for data transmission
2	Tx-	Negative pole for data transmission
3	Rx+	Positive pole for data receiving
4	--	N/C
5	--	N/C
6	Rx-	Negative pole for data receiving
7	--	N/C
8	--	N/C






8-1



[Figure 6]

### ■ Disconnecting CMC-MOD01 from C2000

- Switch off the power supply of C2000.
- Remove the two screws (see Figure 6).
- Twist open the card clip and insert the slot type screwdriver to the hollow to prize the PCB off the card clip (see Figure 7).
- Twist open the other card clip to remove the PCB (see Figure 8).



[Figure 7]

[Figure 8]

### ■ LED Indicator & Troubleshooting

There are 2 LED indicators on CMC-MOD01. The POWER LED displays the status of power supply, and the LINK LED displays the connection status of the communication.

### ■ LED Indicators

LED	Status	Indication	How to correct
POWER	Green	On	Power supply in normal status
	Off	No power supply	Check the power supply
LINK	Green	On	Network connection in normal status
	Flashes	Network in operation	--
LINK	Off	Network not connected	Check if the network cable is connected

### ■ Troubleshooting

Abnormality	Cause	How to correct
POWER LED off	AC motor drive not powered	Check if AC motor drive is powered, and if the power supply is normal.
	CMC-MOD01 not connected to AC motor drive	Make sure CMC-MOD01 is connected to AC motor drive.
LINK LED off	CMC-MOD01 not connected to network	Make sure the network cable is correctly connected to network.
	Poor contact to RJ-45 connector	Make sure RJ-45 connector is connected to Ethernet port.
No module found	CMC-MOD01 not connected to network	Make sure CMC-MOD01 is connected to network.
	PC and CMC-MOD01 in different networks and blocked by network firewall.	Search by IP or set up relevant settings by AC motor drive keypad.
Fail to open CMC-MOD01 setup page	CMC-MOD01 not connected to network	Make sure CMC-MOD01 is connected to the network.
	Incorrect communication setting in DCISoft	Make sure the communication setting in DCISoft is set to Ethernet.
Able to open CMC-MOD01 setup page	PC and CMC-MOD01 in different networks and blocked by network firewall.	Conduct the setup by AC motor drive keypad.
	Incorrect network setting in CMC-MOD01	Check if the network setting for CMC-MOD01 is correct. For the Intranet setting in your company, please consult your IT staff. For the Internet setting in your home, please refer to the network setting instruction provided by your ISP.
Fail to send e-mail	Incorrect network setting in CMC-MOD01	Check if the network setting for CMC-MOD01 is correct.
	Incorrect mail server setting	Please confirm the IP address for SMTP-Server.

## 注意事項 .....

- 此安裝手冊只提供電氣規格、一般規格、安裝及配線等。詳細關於 CMC-MOD01 包含的網路協定內容，請參閱相關的專業文章或藉由資料。交流馬達驅動器安裝環境及方式及注意事項請參考交流馬達驅動器手冊。
- 安裝本產品時，請先關閉交流馬達驅動器電源。交流馬達驅動器的內部電路板有 CMOS IC 極易受靜電的破壞，故在未做好防靜電措施前請勿用手觸摸。造成危險及損壞，且請勿在上電時觸摸任何端子。
- 本機屬於交流馬達驅動器之配件卡，使用者使用本產品時，必須將之安裝於 C2000、CH2000、CP2000、CT2000 及 AFE2000 系列交流馬達驅動器上。
- 電路板上的 IC 易受靜電破壞，未做好防靜電措施前請勿用手觸摸。防止非維護人員操作或意外衝擊本體，造成危險及損壞，且請勿在上電時觸摸任何端子。
- 請務必仔細閱讀本安裝說明，並依照說明指示進行操作，以免造成產品受損，或導致人員受傷。


## 1 產品簡介

感謝您使用台達 CMC-MOD01 通訊卡。CMC-MOD01 定義為 MODBUS TCP 通訊卡，用於將台達 C2000、CH2000、CP2000、CT2000 及 AFE2000 系列交流馬達驅動器接入 MODBUS TCP 網路。CMC-MOD01 無需外接電源，由交流馬達驅動器提供。

### ■ 功能特色

- 支援 MODBUS TCP 協定
- MDI/MDI-X 自動偵測
- 傳輸速率 10/100Mbps 自動偵測
- 電子郵件警報
- 交流馬達驅動器操作器 / Ethernet 組態設定
- 虛擬序列埠

### ■ 產品外觀



[圖 1]

- 螺絲固定孔
- 通訊卡定位孔
- 交流馬達驅動器連接埠

- LINK 指示燈
- RJ-45 連接埠
- POWER 指示燈

- 通訊卡防呆溝槽

## 2 功能規格

### ■ 網路介面

接頭	RJ-45 with Auto MDI/MDIX
埠數	1 Port
傳輸方式	IEEE 802.3, IEEE 802.3u
傳輸線	Category 5e shielding 100M
傳輸速率	10/100 Mbps Auto-Detect
網路協定	ICMP, IP, TCP, UDP, DHCP, HTTP, SMTP, MODBUS OVER TCP/IP, Delta Configuration

### ■ 電氣規格

重量	25g
絕緣電壓	500VDC
消耗電力	0.8W
電	